POWER ENGINEERS, LLC

Electrical Engineering, Power, Lighting, Technical Studies and Utility Consulting

P.O. Box 608 Shrewsbury, MA 01545-0608 (508) 612-0382 Phone (508) 845-5220 Fax Dave@PowerEngineersLLC.com

October 28, 2010

Mr. Hank Ouimet Weston & Sampson Engineers 5 Centennial Drive Peabody, MA 01960

Via Email

Subject:

Electrical Evaluations for Proposed PV Site Landfill, Sharon MA

Dear Hank,

Power Engineers, LLC has completed its review of the possible interconnection of a proposed 2MW photovoltaic (PV) system, to be located at the Town's Landfill on Mountain Street in Sharon, MA. This report details the existing electrical utility infrastructure and upgrades that would be required.

Existing Infrastructure

The existing Landfill site consists of a 15-16 acre (usable area) capped landfill and a small single building. The building has an existing 200 ampere, single-phase 120/240V electrical service, supplied from a single polemount utility transformer (rated 37.5kVA) located on a pole outside of the building. This service is fed off of the side street to the site (Whippoorwill Road) via overhead single-phase primary pole line, owned by National Grid.

The street in front of the site is Mountain Street. This roadway has a single-phase primary pole line owned by National Grid. The closets pole to the existing landfill access driveway is Pole #30 across Mountain Street. This primary overhead line is fed by a three-phase 13.8kV circuit from the north on Mountain Street. The three-phase primary terminates at Spring Street which is 0.25 miles to the north. This circuit is from the <u>National Grid Stoughton Substation</u> on Washington Street, which is located approximately 4 miles to the northeast of the site.

The existing infrastructure along Mountain Street being only single-phase does not have the capacity for a 2.0MW PV project. A 2.0MW (DC) PV project is likely to inject 1.6MW (AC) into the power grid due to the typical DC-AC derating of 0.80 to 0.77 from transformation through the inverters. The single-phase transformer on-site is rated only 37.5kVA and does not have the capacity for this scale of PV project either. See Figure 1 below for a photograph of the existing pole line on Mountain Street. See Figure 2 below for a photograph of the existing building on site and its electrical service pole.



Figure 1 - Existing Pole Line along Mountain Street



Figure 2 - Existing Building and Electric Service Drop On-Sile

Possible Interconnection Points

Give the proposed size of the PV project and the remoteness of the site there is only one point of interconnection that will make technical and ecoromic sense. This will involve the extension of the existing three-phase National Grid 13.8kV circuit along Mountain Street from where it stops at Spring Street (0.25 miles north of the site) to the site location. The wire size of this circuit appears to be 336kemil aluminum conductor, suitable for at least 8MW of load, and appears to have had some upgrades north of the site in the vicinity of the Middle School on Mountain Street.

In order to accommodate a 2MW PV system the new primary three-phase 13.8kV overhead circuit would be extended to the site from Spring Street down Mountain Street. From the closest Pole

#30, a new tap would be made across the street to two new poles. The first pole would contain the utility company's primary metering cluster; which will meter the project as required by utility tariffs.

The second new pole would contain a three-phase group-operated switch, to be switch location to disconnect the system if necessary by the local utility. The pole would also serve as the underground conduit and cable riser to the PV system

From the pole riser underground 15kV three-phase primary cable would go to a padmounted switch cabinet and padmount metering cabinet. The metering cabinet would contain the customer's self-read meter for Renewable Energy Credits (REC's) and for third party reporting of production. The padmount switch would include a vacuum interrupter, which is a high voltage circuit breaker-like device and a high-end protective relay to trip the PV system for variations in voltage and frequency along with isolation should a fault occur. This protection is required by National Grid and dictated by the industries DG standard IEEE 1547.

From the customer's metering and padmount switch new underground primary 15kV conduit and cable would be installed to each of four (4) inverter locations, each one with a 500kVA (13.8kV-120/208V) step-down transformer and 500kW inverter. The final configuration, number of inverters, panels, etc. will be determined by the selected PV vendor, but this type of configuration is typical, along with the current use of 230-270 watt PV panels.

The proposed interconnection would provide redundant utility-grade relaying to protect the National Grid system from any negative effects of the PV system, should there be a problem, along with protecting their workers from the inverters exporting power into a "dead" line during an outage; which can be a safety issue. These types of protective device would be typical for a project of this size, and would allow protection for variations in voltage, frequency, etc. caused by the inverter. A relay would be included in proposed 15kV padmount interrupter switch, with a redundant relay (for voltage & frequency protection) installed in each inverter (4 total).

National Grid has specific standards and requirements for the interconnection of distributed generation such as the proposed PV system project. The interconnection requirements address electrical system protection, revenue metering, operation, and the configuration of the primary interconnection equipment. National Grid will review the proposed design of the electrical interconnection facilities and will perform analyses to determine the impact of the proposed generation on their electrical distribution system.

The required protective relays for the selected inverter interconnection option will be specified by National Grid based on the results of their system impact study. Based on a review of the National Grid Interconnection Requirements, it is anticipated that the protective features the PV system shall be able to detect are over/under frequency and over/under voltage and overcurrent (via the inverter fuses). Upon sensing conditions that exceed allowable operating limits, the protective features shall disconnect the PV system inverter from the rest of the distribution system. Redundant utility-grade protection is proposed at the inverters and at the padmount vacuum interrupter switch

The underground primary cables to interconnect the inverter transformers would be three, single conductor, 15 kV class, #4/0 AWG, aluminum cables to carry the expected maximum 1.6MW AC

October 28, 2010 Page 4

from the project, with only a minimal (1%) voltage drop. New 15kV class cables should be installed in an underground conduit for physical protection rather than being directly buried.

Recommendation

It is recommended to interconnect the proposed 2MW PV system to a new primary electrical three-phase service from Mountain Street, which will need to be extended and upgraded from the intersection of Spring Street, approximately 0.25 miles to the site. This is the simplest and most cost effective interconnection point, as no other three-phase utility feeder exists in the area for interconnection. This type of interconnection is required of multi-MW distributed generation projects and is being used in other wind and PV projects in Massachusetts.

A budgetary cost estimate has been developed for the proposed interconnection and is attached to this report. The estimated cost is \$571,840, which includes the proposed new medium and 'owvoltage electrical work to get from the street to the 120/208V connect to each inverter (4 total), and all necessary equipment up to (but not including) the new PV inverter and PV panels. The work to reconductor by the utility company and contingencies, etc. are also estimated, bringing the total electrical work to an estimated \$793,392

The proposed interconnection is illustrated on the attached One-Line (Drawing E-1) and Electrical Site Plan (Drawing E-2).

If you have any questions, or require additional information, please feel free to give me a call.

Sincerely,

David J. Colombo, P.E. Principal

Attachments

TOWN OF SHARON 2.0 MW LANDFILL PV PROJECT

PROPOSED ELECTRICAL INTERCONNECTION MATERIALS AND CONSTRUCTION COST ESTIMATE

Item Description	Quantity	Units	Unit Cost			Total Cost
Excavation, Backfill and Compaction for Primary Cable Ductbark (2-4")	2.970	Fect	s	45.00	\$	133,650 00
	2 970	Feel	1	25.00	•	74 253 00
Additional excavation & backfull for 2-2" communications conduits	CALL STOR	Teel	Part	2500	Valle a	1-,230.00
Installation of Primary and Communications Conduits	5,940	Feet	\$	11.00	S	65,340.00
Concrete Encasement of conduits	2,970	Fort	\$	20,00	5	59,400.00
Concrete Pad for New Paomount Transformer	. 4	Ea	S	2,500 00	\$	10,000.00
Grounding of Transformer	4	Ła	5	1,000.00	\$	4,000.00
Concrete Pad for New Padmount Switch & Meter	2	Ea	s	2.500.00	S	5,000.00
Grounding of Switch & Meter Pads	2	Ea	\$	1,000 00	s	2.000.00
Installation of Secondary Conduits to PV System 2-4" w/2-2" Comm	100	Feet	S	00.08	S	00 000.8
Installation of Secondary Cable to PV System, 4 sets 3W-600MCM	100	Feet	S	136 00	S	13,600.00
New Distruction Panel for Aux Equipment	1	Lot	5	10,000 00	S	10,000.00
Installator of New Electric Manholes	2	Ea	5	7,000 30	\$	14,000 00
Installation of New Communication Handholes (10"x18"x20")	4	Ea	S	900 006	s	3,600 00
Padmount Transformers 4 x 500kVA each installed	4	Ea	\$	22,000 00	S	88,000.00
Padmount Primary Switch Installed	1	Ea	\$	45,000 00	S	45,000 00
Padmount Primary Metering Cabinet installed	1	Ea	\$	25,000.00	5	25,000 00
New Overhead Pole line work (2 poles w/ switch & nser)	1	Lot	S	00 000,3	S	8,000 00
Site Restoration - Loaming and Seeding (Manhole / Trench area only)	1	Lot	\$	3.000.00	s	3,000.00
		and and		a the same	ali tre	
SUBTOTAL - CONSTRUCTION Contractor Markup, Instirance, Permits, etc. Additional Electrical Equipment and Testing (Control Wingo, Control Electricity, Start-up, etc.)	10% 10%	of subtota of subtota	le l		\$ \$ \$	571,840.00 57,184 00 57,184 00
Estimated Utility Backcharges Contingency TOTAL ESTIMATE	10%	of subtota	al		5 5 5	50,000 00 57,184 00 793,392,00

NOTES:

1. Cost Estimate is budgetary for planning purposes and does not include permitting, legal, financing

and other costs beyond those listed above

Cost Estimate does not include communication cable, as type is unknown at this time.
Cost Estimate is for interconnection and does not include PV inverter or Panels

4. An interconnection to 4- 500kW PV inverters is assumed.

Power Engineers, LLC 10/28/2010





planning, permitting, design, construction, operation, maintenance



Town of Sharon, Massachusetts Weston & Sampson Project No. 2100581

December 3, 2010

Mr. Eric Hooper DPW Director Town of Sharon 217R South Main Street, Box 517 Sharon, Massachusetts 02067

Re: Sharon, Massachusetts – Mountain Street Sanitary Landfill Solar Facility Project (Draft)

Dear Mr. Hooper:

Weston & Sampson has completed the first two tasks of our contract on the above referenced project. The first task was to look into what would be required to provide an interconnection point between the proposed solar facility at the landfill and the existing electrical services in that area. The second task was to inspect the landfill and based on that inspection provide a cost estimate to perform the work needed to bring the landfill into compliance, if necessary, with the Solid Waste Regulations so that the solar facility could be constructed. A more detailed description of the work provided for each task is covered below.

Task 1 was to evaluate the interconnection potential for a 2 MW photovoltaic solar power facility at the Mountain Street Landfill. The evaluation indicates that there is only single-phase electrical service on Mountain Street in the vicinity of the landfill and that three-phase power will need to be run approximately 0.25 miles from Spring Street located north of the proposed facility. National Grid is the local electrical provider for this area. The interconnection evaluation was performed by Power Engineering, LLC and a copy of the interconnection electrical evaluation is attached as Attachment A.

Based on Power Engineering's evaluation, it is recommended that a new primary electrical threephase service be extended from Spring Street to the site. This would be the simplest and most cost effective interconnection point and this type of interconnection point is required for multi-MW distributed generation projects. The evaluation has determined that it will cost approximately \$793,392 to provide an interconnection point for the proposed 2 MW facility at the landfill.

Massachusetts Peabody (HQ) Foxborough Woburn Bourne Chatham South Yarmouth ConnecticutRhode IslandRocky HillCoventry

New Hampshire

Maine Vermont York Waterbury New York Poughkeepsie New Jersey Pennsylvania Cinnaminson Pottstown Edison Florida Fort Myers Sarasota

Mr. Eric Hooper December 3, 2010 Page 2

Task 2 was to provide a cost estimate for repairs at the landfill in order to bring the landfill into compliance with the 310 CMR 19.000, Solid Waste regulations, which would allow the site to be used for the solar facility. Weston & Sampson performed a semi-annual inspection of the landfill capping system during October 2010. This inspection was part of the requirements of the landfill's Post-Closure Monitoring and Maintenance Plan. That inspection report has been submitted to the DEP and the Town. A copy of the landfill inspection report is attached as Attachment B. The inspection indicates that the landfill needs to be mowed in order to remove woody vegetation from the landfill surface. In addition, all woody vegetation needs to be removed from drainage swales and detention basins. The perimeter drainage swales around the landfill need to be surveyed to verify areas of negative drainage. Storm water was noted standing in many locations. In addition, there are other minor items that should be addressed as noted in the inspection report. Weston & Sampson, based on the results of that inspection, developed a cost estimate to perform the work necessary to bring the landfill into regulatory compliance. The cost estimate to repair the landfill is approximately \$35,400 (see Attachment B).

Please review the attached information and call us if you have questions or provide us with comments. Once we have discussed any issues with this information, we will issue a final letter documenting the interconnection and the landfill repairs. Upon the acceptance of this information, we can then move forward with the development of solar facility RFP.

Please call if you have any questions or require additional information.

Very truly yours,

WESTON & SAMPSON

erous C. Vernes Duane C. Himes, P.E., P.L.S.

Team Leader

Attachments

cc: File

O:\Sharon MA\Sharon Landfill Solar\Solar Farm letter Hooper.doc