

**PFAS6 Concentration
uh/l (PPT)**

	Well #2	Well #3	Well #4 Raw	Well #4 Treated	Well #5	Well #6	Well #7
4/6/2021	19.5	6.2	88.8		0.0	2.2	8.6
5/4/2021	19.8	5.9	78.6			9.2	4.3
6/7/2021	34.0		125.7				
6/21/2021				0.0			
6/23/2021			78.7	0.0			
7/14/2021	23.0	13.1	73.1	0.0		10.0	5.7
8/12/2021	38.4	10.2	75.3	0.0	0.0	9.1	5.4
9/16/2021	34.8	13.1	100.7	0.0	0.0	15.1	7.1
10/13/2021	38.9	13.9	83.8	0.0		17.2	6.8
11/18/2021	33.0	13.2	93.7	0.0		11.8	6.0
12/16/2021	27.7	12.2	82.2	0.0		6.8	6.0
1/13/2022	31.0	6.9	70.6	0.0	0.0	5.9	4.9
2/10/2022	20.6	7.1	82.0	0.0		6.0	4.6
3/10/2022	19.2	6.2	69.4	0	0	6.4	4
4/14/2022	27.8	6.7	73.1	0	0	7.4	0
5/12/2022			62	0			
6/16/2022			77	0			
7/18/2022	50.9	18.3	86.4	0		12.3	
8/25/2022			108.2	0			
9/15/2022		19.4	121.9	0			
10/20/2022	40.5		103.85	0		12.1	10.5
11/14/2022			128	0			
12/14/2022			108.3	0			
1/19/2023	45.4	15.9	111.6	0		12.4	
2/22/2023	29.3		81.2	0			
3/10/2023	37.6		85.3				
4/25/2023	38.7	12.7	84.4			11.3	
5/18/2023	40.3		89.7	0			
6/15/2023	40.5		93.3	0			
7/25/2023	50.1	19.6	95.2	0		11.5	
8/11/2023	46		94	0			
8/17/2023		20					
9/14/2023	41	16	91	0			

Blue = well not in use

Red = untreated water - not in system